

Certificate of Compliance This certificate is issued for the following:

Steel Pipe for Use with Aboveground Fire Protection Systems

Pipe Specification Outsi

NPS, mm Outside Diameter/ Wall Thickness

End Connections

EN 10217

33.7 x 2.0, 42.4 x 2.0, 48.3 x 2.0, 60.3 x 2.0, 76.1 x 2.0, 88.9 x 2.0, 114.3 x 2.3, 139.7 x 2.9, 168.3 x 2.9, 219.1 x 3.6

Rolled Groove

Prepared for:

Sprinkler Nordic AB Ostra Bangatan 8 Arlandastad, SE-195 60 Sweden Manufactured at:

Tecno Tubi SpA Via Mazzani 240/242 Alfianello (BS) Italy

FM Approvals Class: 1630 – "Steel Pipe for Automatic Fire Sprinkler Systems"

Approval Identification: 3049678 Approval Granted: October 31, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne

Manager, Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062



Member of the FM Global Group