


Installation guide

Pressure switch

KP 1E, KP 6EW, KP 6EB, KP 7EW, KP 7EB



© Danfoss | DCS (rm) | 2019.09

Janfoss



The KP-E pressure switch placed in explosive zone must always be wired through reliable Ex zener barrier, placed outside ex-zone, to ensure insufficient energy supply to cause the ignition of surrounding atmosphere by an electrical spark or the heating of components of circuitry.

Cables and cable entries approved for the application must be used and can not be in contact with sharp edges. Cables must be connected with adequate stress relief that way that pulling forces can not be carried throug the cable to the terminal. Use the tightening torque of max. 2 Nm.


A particular system can be classified in different zones, for

Note:

different parts of the system.

The equipment to be used for electrical load limiting must always be approved for use in the zone concerned.

Intrinsic safety protection method



Pantoss

Safety requirements

- 1. The KP-E can be applied on systems with R290, R32, R444B, R600, R600a, R1234ze, R1290 as the working fluid. For countries where safety standards are not an indispensable part of the safety system Danfoss recommend the installer to get a third party approval of the system containing flammable refrigerant.
- Note, please follow specific selection criteria stated in the datasheet for these particular refrigerants.
- 2. The refrigeration system must always comply with European Ex installation standard, EN 60079-14, any local directive and legislation as well as any other regulation applying in the area of installation.
- **3.** KP-E switch must be used only with reliable means of limiting the voltage and current to prevent sparks between the contact surfaces. The equipment to be used for electrical load limiting must always be approved for use in the zone concerned.
- 4. Cable and cable entries approved for the application must be used. Cables must not be in contact with sharp edges. The cable must be connected with adequate stress relief in order to prevent that pulling forces can be carried through the cable to the terminal.
- 5. In the event of pressure pulsations in the system, where the switch is connected, these must be effectively damped to prevent fatigue failure on the bellows. The cycle frequency of the KP-E switch must be kept as low as possible. The vibration level must be kept as low as possible.
- 6. It is recommended to regularly check the function of the KP-E switch.
- Only apparatus designed, constructed and released by Danfoss must be used for application concerned. Danfoss can accept no responsibility in case of alterations made on the pressure switches or the use of them against the instructions of Danfoss.
 Any overload of the KP-E switch must be prevented. Overloaded or damaged apparatus must be exchanged.
- Only authorised persons, who are certified in installing and maintaining refrigration system may do the installation, maintenance and exchange of the switch.
- **10.** Use only appropriate tools.
- **11.** Dispose of the switch in an environmentally-friendly way.
- 12. KP-E switches must be installed in area where is low risk of mechanical damage.
- **13.** Components within the equipment can exceed the enclosure temperature by 1K (1 °C). When the media temperature exceeds 80 °C, it is the responsibility of the user to ensure that the media temperature does not cause a thermal ignition risk on parts between the media and the switch enclosure thus it is recommended that maximum media temperature on pressure switch is limited to 80 °C.
- 14. Isolation of the intrinsically safe circuit to ground and to the contact mounting screw has been verified through 500VACrms dielectric strength testing, carried out in accordance with IEC EN 60079-11:2012.
- **15.** The max. applicable length of the cable connected to the KP-E depends on cable capacity and inductivity. Capacitance and inductivity of the cable together with Ci and Li of KP-E must fit requirements of applied zener barrier.



ENGINEERING TOMORROW

> Danfoss A/S 6430 Nordborg Denmark CVR nr.: 20 16 57 15

Telephone: +45 7488 2222 Fax: +45 7449 0949

EU DECLARATION OF CONFORMITY

Danfoss A/S

Refrigeration & Air Conditioning Controls

declares under our sole responsibility that the **Product category:** Pressure switches **Type designation(s):** KP1E, KP7EW, KP7EB, KP6EW, KP6EB, KP6ES

Covered by this declaration is in conformity with the following directive(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

Explosive or Protective Systems Intended for use in Potentially Explosive Atmospheres, Directive 2014/34/EU



II 3G

Ex ic IIB T6 Gc Tamb. -20°C to +60°C

<u>Test basis:</u> EN 60079-0:2012 + A11:2013 Explosive atmospheres, Part 0, Equipment-General requirements EN 60079-11:2012 Explosive atmospheres, Part 11, Equipment Protection by Intrinsic safety "i".

Pressure Equipment Directive 2014/68/EU

Equipment cat:IV

Notifying Body: TÜV Rheinland, Notified Body No.: 0035.

Test basis: EN 12263:1998 Refrigerating systems and heat pumps – Safety switching devices for limiting the pressure, Requirements and tests.

Conformity assessment: module B (production type), TÜV certificates: 01 202 931-B-10-0003-02 and 01 202 641/B-19 0006 module D, TÜV certificate 01 02 PL/Q-11-0004

RoHS Directive 2011/65/EU and 2015/863/EU

EN 50581:2012 Technical documentation for the assessment of electrical and electronics products with respect to the restriction of hazardous substances

Date: 2019.07.10	Issued by	Date: 2019.07.10 Approved by
Place of issue:	DEC. 1. Ka	Place of issue:
Grodzisk Maz.	FION Myvamen	Grodzisk Maz.
	Signature:	Signature:
	Name: Piotr Chylaszek	Name: Lukasz Stasiowski
	Title: Atex Authorized Person	Title: RD&E Manager

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the pectation being translated into any other language, the translator concerned shall be liable for the correctness of the translation