

## **Declaration of Conformity**

We, AHLSELL AB  
117 98 STOCKHOLM, SWEDEN

Ensure and declare that apparatus:

**EM111 E09 100 01**

With the measurement range

**1x230V, 0.25-5(45)A, 50Hz, 1000imp/kWh**

Are in conformity with the type as described in the

**EC-type examination certificate 0120/SGS0282**

And satisfy the appropriate requirements of the Directive 2014/32/EU with the following standards:

EN 50470-1: 2006, Electricity metering equipment (AC) Part 1: General requirements, tests and test conditions. Metering equipment (class indexes A, B and C)

And

EN 50470-3: 2006, Electricity metering equipment (AC) Part 3: Particular requirements  
- Static meters for active energy (class indexes A, B and C)



Company stamp and signature