

Certificate



Intertek


for European Product Safety

Reference No. 1211224

Duct fan

Type designation	K****
Certificate holder	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
The product complies with the standard(s)	EN 60335-1:2012 EN 60335-2-80:2003+A1+A2 EN 62233:2008
Date of expiry	16 February 2018
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 _____ Niclas Lood	Date	16 February 2013 Page 1 of 5

This certificate is issued in accordance with the terms and conditions set out in the Appendix.



Intertek
Appendix

Reference No. 1211224

Technical data

Type designation	K 100 M
Rated voltage (V)	230
Rated power (W)	30
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 100 XL
Rated voltage (V)	230
Rated power (W)	58
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 125 M
Rated voltage (V)	230
Rated power (W)	29
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 125 XL
Rated voltage (V)	230
Rated power (W)	62
Frequency (Hz)	50
Class	I
IP-Class	44

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek
Appendix

Reference No. 1211224

Type designation	K 150 M
Rated voltage (V)	230
Rated power (W)	64
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 150 XL
Rated voltage (V)	230
Rated power (W)	104
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 160 M
Rated voltage (V)	230
Rated power (W)	63
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 160 XL
Rated voltage (V)	230
Rated power (W)	105
Frequency (Hz)	50
Class	I
IP-Class	44

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek
Appendix

Reference No. 1211224

Type designation	K 200 M
Rated voltage (V)	230
Rated power (W)	106
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 200 L
Rated voltage (V)	230
Rated power (W)	159
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 250 M
Rated voltage (V)	230
Rated power (W)	103
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	K 250 L
Rated voltage (V)	230
Rated power (W)	157
Frequency (Hz)	50
Class	I
IP-Class	44

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

**Intertek
Appendix***Reference No. 1211224*

<i>Type designation</i>	K 315 M
<i>Rated voltage (V)</i>	230
<i>Rated power (W)</i>	203
<i>Frequency (Hz)</i>	50
<i>Class</i>	I
<i>IP-Class</i>	44


<i>Type designation</i>	K 315 L
<i>Rated voltage (V)</i>	230
<i>Rated power (W)</i>	314
<i>Frequency (Hz)</i>	50
<i>Class</i>	I
<i>IP-Class</i>	44

<i>Manufacturing site(s)</i>	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
------------------------------	---

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

<i>Certification Body</i>	Intertek Semko AB, Product Certification	<i>Place</i>	Kista - Stockholm
---------------------------	--	--------------	-------------------

<i>Signed</i>	 _____ Niclas Lood	<i>Date</i>	16 February 2013
---------------	---	-------------	------------------

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.